

EVACUATION PLAN

Destined for the premises of ÚOCHB AV ČR, v.v.i., C Flemingovo nám. 2, Praha 6

Person responsible to control the evacuation: Director, vice-director
and/or head of department
Place of the evacuation control Main gatehouse in building A

Persons and means ensuring the evacuation

Heads of the scientific teams shall ensure evacuation of persons, animals and important documents depending on circumstances and speed of spreading the fire. All the employees shall help with evacuation of technical gas pressure bottles and important material from endangered premises and also with evacuation of easily movable precious working site equipment.

A list of objects of evacuation in order of importance must be made out in advance and kept in the working site. It is strictly forbidden to use a lift for evacuation. Operable lift must be preferably used to move technical gas pressure bottles out of the endangered premises and then to evacuate heavy precious equipment always without attendance of persons (a loaded lift must be called to a save floor by means of a button).

Ways of evacuation / escape ways Corridors, stairways

Place and centralization of persons and evacuated material Park on Flemingovo nám. 2, Praha 6

Responsible person to check a number of persons Particular heads

First aid shall be provided by Company employees having
medical qualification and the

first Aid Medical

Service **Phone No. 155**

Responsible person to watch the evacuated material Employee designated by the
person responsible for the evacuation

course

INTERNAL EQUIPMENT

Fire-extinguishing hydrants are located In corridors and in the company premises
(underground hydrants)

Portable fire extinguishers are located In corridors, in rooms

Mobile fire extinguishers are located In the premises or in corridors

Main gas lock It is located on the -1st floor and outside the building
C on the corner of the Zelená and
Stavitelská streets

Electric current main switch It is located on each floor, central electric current
switch is on the -1st floor

Main water stop in the premises Is located on the -1st floor

Other equipment (to be completed) **Lift must not be used for evacuation of persons !**

Michal Pošta
Fire safety qualified person

RNDr., PhDr. Zdeněk Hostomský, CSc.
Director of ÚOCHB AV ČR, v.v.i.

In Prague on 1 September 2015